



# Certificate of Compliance

This certificate is issued for the following equipment:

## Automatic Sprinklers for Fire Protection

| Model | K   | Type              | Resp. | Element | NPT (in.) | Finishes | Temperature Ratings °F (°C) |
|-------|-----|-------------------|-------|---------|-----------|----------|-----------------------------|
| RD106 | 5.6 | Concealed Pendent | SR    | Fusible | 1/2       | Brass    | 162, 205 (72, 96)           |

Prepared for:

Rapidrop Global Ltd.  
Rutland Business Park, Newark Road  
Peterborough, PE1 5WA, United Kingdom

FM Approvals Class: 2015

FM Approval Standard: Class Number 2000 (February 2018)

Approval Identification: PR467075

Approval Granted: 17 October 2023

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D. B. Fuller', is written over a horizontal line.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062  
USA

