

# HMER.EX15304 - Check Valves

## Check Valves

**RAPIDROP GLOBAL LTD**  
 RUTLAND BUSINESS PARK  
 NEWARK RD  
 PETERBOROUGH, PE1 5WA United Kingdom

EX15304

Model	Type	Valve Seat Facing	Nom Pipe Size, NPS	End Config	Rated Pressure, psig	Installation Position
302	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	300	H, V
304-060	Swing	Elastomeric	2	G by G	350	H, V
304-073	Swing	Elastomeric	2-1/2	G by G	350	H, V
304-076	Swing	Elastomeric	2-1/2	G by G	350	H, V
304-089	Swing	Elastomeric	3	G by G	350	H, V
304-114	Swing	Elastomeric	4	G by G	350	H, V
304-139	Swing	Elastomeric	5	G by G	350	H, V
304-141	Swing	Elastomeric	5	G by G	350	H, V
304-165	Swing	Elastomeric	6	G by G	350	H, V
304-168	Swing	Elastomeric	6	G by G	350	H, V
304-219	Swing	Elastomeric	8	G by G	350	H, V
305-050	Swing	Elastomeric	2	F by F	350	H, V
305-065	Swing	Elastomeric	2-1/2	F by F	350	H, V
305-080	Swing	Elastomeric	3	F by F	350	H, V
305-100	Swing	Elastomeric	4	F by F	350	H, V
305-125	Swing	Elastomeric	5	F by F	350	H, V
305-150	Swing	Elastomeric	6	F by F	350	H, V
305-200	Swing	Elastomeric	8	F by F	350	H, V
CVF300	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	F by F	300	H, V
301	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	G by G	300	H, V

302 PN16	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	300	H, V
303	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, 14, 16	W	300	H, V
Fig.306	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	G by G	365	H, V
Fig.306P	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	G by G	365	H, V
Fig.307	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	F by F	300	H, V
Fig.308	Swing	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	Wafer	300	H, V

End Configuration:

F - Flanged


G - Grooved

W - Wafer

Installation Position:

H - Horizontal installation

V - Vertical installation

Trademark and/or Tradename: "Rapidrop", 

Last Updated on 2022-08-24

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2022 UL LLC."